



Municipal Corporation

Near fountain chowk, Railway road
YamunaNagar (Haryana) - 135001
91-1732-260227, 237841



www.mcynr.com | mc.yamunanagar@gmail.com | 1800 3070 9777 | MC Yamunanagar

Inspection Report

क्रमांक:- 7528

दिनांक:- 22/8/25

आज दिनांक 22.08.2025 को नगर निगम यमुनानगर द्वारा D.A.V Public School, Professor Colony Ward no. 08 में स्कूल की सफाई व्यवस्था का निरीक्षण किया गया निरीक्षण के दौरान स्कूल के सभी शौचालय स्वच्छ और अच्छी साफ सफाई पाई गई। स्कूल में गिरे व सूखे कूड़े के प्रबंधन के लिए कूड़ादान भी लगाये गये हैं।

मुख्य सफाई निरीक्षक,

Vinod Beniwal
मुख्य निगम यमुनानगर जगाधरी
Chief Sanitary Inspector
Municipal Corporation
Yamunanagar-Jagadhri

**PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, YAMUNANAGAR**



Website :- <https://phedharyana.gov.in/>

Memo No:- 270

Date:- 09/03/2026

TC-16830

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/ Lab Ref. No. : YNR/10853/2/2026//C-1355	Sample Details	Date & Time
Classification: Private	Sample Provided by	Narender Kumar
Customer Ref. No. : Memo. No. Nil Dt. : 02/03/2026	Sample Receiving at Lab	02/03/2026
Sender : Principal D.A.V Public School	Analysis Start Date	03/03/2026
Location : Professor Colony, Distt.Yamuna Nagar	Analysis End Date	05/03/2026
Sample Description : Drinking Water	Sample Quantity	2 ltr
Type of Analysis : Chemical Analysis	Source of Sample: Self Submersible at D.A.V Public School, Professor Colony, Distt.Yamuna Nagar	
Packing, Marking & Seal : Unsealed Plastic Bottle		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Protocol Used	Unit	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)
1	Total Dissolved Solids@ 180°C ± 2°C	APHA 24 th Edition-2540 C :2023	mg/lt.	110	500	2000
2	Total Hardness as CaCo3	APHA 24 th Edition-2340 C :2023	mg/lt.	54.45	200	600
3	Calcium as Ca	APHA 24 th Edition-3500- Ca B	mg/lt.	13.88	75	200
4	Magnesium as Mg	APHA 24 th Edition-3500 Mg B	mg/lt.	4.81	30	100
5	Chloride as Cl	APHA 24 th Edition-4500 Cl -B	mg/lt.	17.49	250	1000
6	Fluoride as F	APHA 24 th Edition-4500 F C	mg/lt.	0.36	1.0	1.5
7	Nitrate as No3	APHA 24 th Edition-4500 No3 B	mg/lt.	1.14	45	45
8	pH @ 25°C	APHA 24 th Edition 4500 -H ⁺ B	pH Unit	7.29	6.5-8.5	6.5-8.5
9	Total Alkalinity	APHA 24 th Edition-2320 B	mg/lt.	57	200	600
10	Color	APHA 24 th Edition-2120 B /2120 C	Hazen Unit	<5	5	15
11	Odour	IS 3025 (PART-5)	Qualitative	Agreeable	Agreeable	Agreeable
12	Taste	IS 3025 (PART-8)	Qualitative	Agreeable	Agreeable	Agreeable
13	Turbidity	APHA 24 th Edition-2130 B	NTU	<1	1	5
14	Iron as Fe	USEPA 45(126:43459)	mg/lt.	<0.10	1.0	No Relaxation
15	Sulphate as So4	IS 3025 (PART 24) : 2022	mg/lt.	11	200	400

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED YAMUNA NAGAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * The test samples meant for chemical analysis will be disposed off after 07 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: *Vaishali* & *Sukhvinder*
(Water Analyst)

Reviewed by: *Neeraj Mehta*
Authorized Signatory/Chemist
PHED Water Testing Laboratory
Yamuna Nagar

Neeraj Mehta
Authorized Signatory/Chemist
PHED Water Testing Laboratory
Yamuna Nagar

Principal

**D.A.V. PUBLIC SCHOOL
YAMUNA NAGAR**

END OF TEST REPORT